

# TITLE 24 COMPLIANCE REVIEW

## 2019 JUVENILE REGULATIONS

<b>JURISDICTION:</b> <b>FACILITY:</b> <b>ADDRESS:</b> <b>PROJECT TITLE:</b> <b>BSCC GRANT PROJECT #:</b>		<b>BSCC PLAN REVIEW #:</b>
		<b>FACILITY TYPE:</b> <b>SECURITY LEVEL: Min-Max</b>
<u>Schematic Design Review</u>	<u>Design Development Review</u>	<u>Construction Document Review</u>

This *Review* document is intended for use in conjunction with the 2019 California Building Code, Title 24 Parts 1 and 2, *Minimum Standards for Local Juvenile Facilities*. To verify compliance with Title 24 regulations, this review document will be used in the evaluation of Schematic Design (SD), Design Development (DD) and Construction Document (CD) submittals of Juvenile Halls, Juvenile Camps and Special Purpose Juvenile Halls. It is not anticipated or expected that full compliance will be achieved until the CD phase of project development. Final project compliance is determined prior to facility opening at the on-site physical plant evaluation.

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	REFERENCE	REGULATION NARRATIVE
						<i>Title 24, Part 1</i>	<b><u>Effective January 1, 2020</u></b>
						13-201(c)3	<b><u>OPERATIONAL PROGRAM STATEMENT</u></b>
						13-201(c)6.A	<b><u>DESIGN REQUIREMENTS</u></b> – The design of a local juvenile facility shall comply with provisions of California Code of Regulations, Title 24, Part 2, Section 1230.
						13-201(c)6.B	<b>The design of a juvenile facility shall address the following:</b>
						13-201(c)6.B(1)	<b><u>Fire safety.</u></b> The provisions of Title 19 and Title 24 as adopted by the State Fire Marshal as they relate to juvenile facilities shall be incorporated into the facility design.

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						13-201(c)6.B(2)	<b>Suicide hazards.</b> Architectural plans shall be reviewed by the Board for the purpose of reducing hazards posed by fixtures and equipment which could be used for an act of suicide by a youth. The facility design shall avoid any surfaces, edges, fixtures, or fittings that can provide an attachment for hanging or other opportunity for self-inflicted injury. The following features shall be incorporated in the design of sleeping rooms, bathrooms, and any other area where a juvenile may be left alone:
						13-201(c)6.B(2)(a)	Plumbing shall not be exposed. Operation of control valves shall use flush buttons or similar. Drinking water spout, if any, shall be without curved projections;
						13-201(c)6.B(2)(b)	Towel holders shall be ball-in-socket or indented clasp, not pull-down hooks or bars;
						13-201(c)6.B(2)(c)	Supply and return grilles and any other vent or security cover shall have openings no greater than 3/16 inch or have 16-mesh per square inch;
						13-201(c)6.B(2)(d)	Beds, desk surfaces, and shelves shall have no sharp edges and shall be configured to prevent attachment;
						13-201(c)6.B(2)(e)	Light fixtures shall be tamper resistant;
						13-201(c)6.B(2)(f)	Fixtures such as mirrors shall be mounted using tamper resistant fasteners;
						13-201(c)6.B(2)(g)	Fire sprinkler heads inside rooms shall be designed to prevent attachment; and
						13-201(c)6.B(2)(h)	Telephone cords shall be at a length that reduces the potential for use as a ligature.
						13-201(c)6.B(3)	<b>Health and sanitation.</b> Provisions of Subchapter 5, Title 15, California Code of Regulations, and of the California Retail Food Code (CalCode) as they relate to juvenile facilities shall be incorporated into the facility design.

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						13-201(c)6.B(4)	<p>When adding new sleeping rooms to a juvenile hall, not less than 10 percent of them shall be single occupancy, unless the juvenile hall can demonstrate that its current number of single occupancy rooms will equal at least 10 percent of the new rated capacity. In addition, single or double occupancy rooms shall be that number, determined by the facility administrator, necessary to safely manage the population of the facility based on a comprehensive needs assessment which accounts for youth projected to be:</p> <ul style="list-style-type: none"> <li>a. mentally disordered;</li> <li>b. custodial problems, and/or</li> <li>c. likely to need individual housing for other specific reasons as determined by the facility administration.</li> </ul> <p>The total number of single or double occupancy rooms shall be identified.</p>
						13-201(c)6.B(5)	<p><b>Staff and safety.</b> Facilities shall be designed and/or equipped in such a manner that staff and youth have the ability to summon immediate assistance in the event of an incident or an emergency.</p>
						13-201(c)6.B(6)	<p><b>Heating and cooling.</b> Provision shall be made to maintain a generally accepted living environment and meet the requirements of Parts 1 (California Administrative Code), 2 (California Building Code), and 4 (California Mechanical Code).</p>
						13-201(c)6.B(7)	<p><b>Acoustics.</b> Dayroom areas shall be designed and constructed so that the noise level does not exceed 70 decibels and a reverberation time less than 1.5 seconds. Sleeping areas shall have a noise level no higher than 45 decibels and a reverberation time less than 1.5 seconds. The heating, ventilating and air conditioning noise level shall be no higher than 45 decibels in sleeping areas and classrooms.</p>

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<i>REFERENCE</i>	<i>REGULATION NARRATIVE</i>
						13-201(c)6.B(8)	<p><b><u>Spaces for the disabled.</u></b></p> <ul style="list-style-type: none"> <li>a. Other space within the security perimeter such as dayroom and activity areas shall be located such that a disabled youth will not be excluded from participating in any program for which they would otherwise be eligible. An accessible shower for disabled youth shall be available.</li> <li>b. All spaces of a local juvenile facility shall comply with the applicable chapters of Title 24, Part 2 of the California Code of Regulations.</li> </ul>
						13-201(c)6.B(9)	<p><b><u>Security.</u></b> Facility design shall facilitate security and supervision appropriate to the classification level of youth in custody including consideration of design space as it relates to the prevention of sexual abuse, assault and harassment.</p> <ul style="list-style-type: none"> <li>a. The facility perimeter shall be controlled by appropriate means to ensure that youth remain within the perimeter and shall be designed to prevent access by the general public without proper authorization.</li> </ul>
						13-201(c)6.B(9)	<ul style="list-style-type: none"> <li>b. Security glazing shall be used where it defines the secure premier of buildings. It shall also be used at appropriate interior locations to ensure a secure and safe environment for youth and staff.</li> </ul>

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						13-201(c)6.B(10)	<b><u>Medical/mental health care housing and treatment space.</u></b> There shall be some means to provide health care housing and treatment of ill and/or infirm youth. When the operational program statement for a facility indicates that medical care housing is needed, such housing must provide lockable storage space for medical instruments and must be located within the security area of the facility accessible to both female and male youth, but not in the living area of either. Treatment spaces and the medical care housing unit shall be designed in consultation with the health authority. If negative pressure isolation rooms are being planned, they shall be designed to the community standard. Medical/mental health areas may contain other than single occupancy rooms.
						13-201(c)6 B(11)	A sewage system design capable of addressing items that could potentially impact waste water systems.
						13-201(c)6 B(12)	Floor drains shall be provided where operationally and mechanically appropriate.
						<b>Title 24, Part 2</b>	<b><u>Effective January 1, 2020</u></b>
						Section 1230.1	<b><u>DESIGN CRITERIA FOR REQUIRED SPACES</u></b>
						1230.1.1	<b><u>Reception/Intake Admission.</u></b> In each juvenile hall, space used for the reception of youth pending admission to juvenile hall shall have the following space and equipment:
						1230.1.1.1.	Weapons locker as specified in Section 1230.2.9;
						1230.1.1.2.	A secure room for the confinement of youth pending admission to juvenile hall as specified in 1230.1.2;
						1230.1.1.3.	Access to a shower;
						1230.1.1.4.	A secure vault or storage space for youth, valuables;
						1230.1.1.5.	Telephones accessible to youth; and,
						1230.1.1.6.	Access to hot and cold running water for staff use.
						1230.1.2.	<b><u>Locked Holding Room.</u></b> A locked holding room shall:
						1230.1.2.1.	Contain a minimum of 15 square feet of floor area per youth;

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						1230.1.2.2.	Provide no less than 45 square feet of floor space and have a clear ceiling height of 8 or more feet;
						1230.1.2.3.	Contain seating to accommodate all youth as specified in Section 1230.2.8;
						1230.1.2.4.	Be equipped with a toilet, wash basin, mirror and drinking fountain as specified in Sections 1230.2, unless a procedure is in effect to give the youth access to a toilet, wash basin, mirror and drinking fountain;
						1230.1.2.5.	Maximize visual supervision of youth by staff; and
						1230.1.2.6.	Have an outward swinging or lateral sliding door.
						1230.1.3	<b><u>Natural Light.</u></b> Outer-facing exterior windows where youth's privacy is not at risk shall be provided in locked sleeping rooms, single occupancy sleeping rooms, double occupancy sleeping rooms, dormitories and dayrooms. Natural light may be provided by, but is not limited to, skylights or windows in dayrooms, windows in adjacent exterior exercise areas and in sleeping rooms and/or dormitories.
						1230.1.4	<b><u>Corridors.</u></b> Corridors in living units shall be at least 8 feet wide.
						1230.1.5	<b><u>Living Unit.</u></b> A living unit shall be a self-contained unit containing locked sleeping rooms, single and double occupancy sleeping rooms, or dormitories, dayroom space, toilet, wash basins, drinking fountains and showers commensurate to the number of youth housed. A living unit shall not be divided in a way that hinders direct access, supervision, immediate intervention or other action if needed. In juvenile halls, the number of youth housed in a living unit shall not exceed 30.
						1230.1.6	<b><u>Locked Sleeping Rooms.</u></b> Locked sleeping rooms shall be equipped with an individual or combination toilet, wash basin, mirror and drinking fountain. Doors to locked sleeping rooms shall swing outward or slide laterally.

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	REFERENCE	REGULATION NARRATIVE
						1230.1.7	<b><u>Single Occupancy Sleeping Rooms.</u></b> Single occupancy sleeping rooms shall provide the following:
						1230.1.7.1.	A minimum of 70 square feet of floor area;
						1230.1.7.2.	A minimum clear ceiling height of 8 feet; and,
						1230.1.7.3.	The door into this room shall swing outwards or slide laterally and be provided with a view panel, a minimum of 144 square inches, constructed of security glazing.
						1230.1.7.4	Contain beds as specified in 1230.2.5.
						1230.1.8	<b><u>Double Occupancy Sleeping Rooms.</u></b> Double occupancy sleeping rooms shall provide the following:
						1230.1.8.1.	A minimum of 100 square feet of floor area;
						1230.1.8.2.	A minimum clear ceiling height of 8 feet and a minimum width of 7 feet; and,
						1230.1.8.3.	The door into this room shall swing outward or slide laterally and be provided with a panel, a minimum of 144 square inches, constructed of security glazing.
						1230.1.8.4	Contain beds as specified in 1230.2.5.
						1230.1.9	<b><u>Dormitories.</u></b> Dormitories shall provide the following:
						1230.1.9.1.	A minimum of 50 square feet of floor area per youth with the minimum size of a dormitory being 200 square feet of floor area and a minimum 8-foot clear ceiling height;
						1230.1.9.2.	Designed for no fewer than 4 youth;
						1230.1.9.3.	Dormitories in juvenile halls shall be designed for no more than 30 youth;
						1230.1.9.4.	Camps shall conform to Items 1 and 2.
						1230.1.10	<b><u>Dayrooms.</u></b> Dayrooms shall contain 35 square feet of floor area per youth, contain tables and seating to accommodate the maximum numbers of youth allowed access at a given time. Access must be provided to toilets, wash basins, drinking fountains, and showers as specified in Section 1230.2.

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>								
						1230.1.11	<b><u>Physical Activity and Recreation Areas.</u></b> Indoor/outdoor physical activity and recreation areas shall be designed as follows:								
						1230.1.11.1	<table border="0"> <tr> <td><u>Facility Capacity</u></td> <td><u>Minimum Indoor/Outdoor Recreation Space</u></td> </tr> <tr> <td>40 or less</td> <td>9,000 square feet</td> </tr> <tr> <td>41-274</td> <td>225 square feet per youth up to 61,650 square feet</td> </tr> <tr> <td>275 or more</td> <td>61,650 square feet, plus 145 square feet for each youth beyond 274 (up to a maximum of 87120 square feet)</td> </tr> </table>	<u>Facility Capacity</u>	<u>Minimum Indoor/Outdoor Recreation Space</u>	40 or less	9,000 square feet	41-274	225 square feet per youth up to 61,650 square feet	275 or more	61,650 square feet, plus 145 square feet for each youth beyond 274 (up to a maximum of 87120 square feet)
<u>Facility Capacity</u>	<u>Minimum Indoor/Outdoor Recreation Space</u>														
40 or less	9,000 square feet														
41-274	225 square feet per youth up to 61,650 square feet														
275 or more	61,650 square feet, plus 145 square feet for each youth beyond 274 (up to a maximum of 87120 square feet)														
						1230.1.11.1.1	At least one quarter of the dedicated indoor/outdoor space shall be a paved or like surface.								
						1230.1.11.1.2.	The required recreation area shall contain no single dimension less than 40 feet.								
						1230.1.11.2.	A portion of the dedicated space for physical activity and recreation shall be out-of-doors and be of sufficient size and equipped in such a manner to allow compliance with Title 15, Section 1371, which requires at least one hour per day of outdoor activity for each detained youth.								
						1230.1.11.3.	Lighting of outdoor recreation areas shall be provided to allow for evening activities and to provide security.								
						1230.1.11.4.	Access must be provided to a toilet, wash basin and drinking fountain as specified in Section 1230.2.								
						1230.1.12	<b><u>Academic Classrooms.</u></b> There shall be dedicated academic classroom space for every juvenile in every facility. The primary purpose for the academic classroom shall be for education. Each academic classroom shall contain a minimum of 160 square feet of floor space for the teachers' desk and work area and a minimum of 28 square feet of floor space per minor. A communication system shall be provided in each classroom to allow for immediate response to emergencies. The classroom shall be designed for a maximum of 20 minors. There shall be space available in every juvenile facility that may be used for specialized, one-on-one or small group educational purposes.								
						1230.1.13	<b><u>Safety Room.</u></b> A safety room shall:								

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						1230.1.13.1.	Contain a minimum of 48 square feet of floor area and a minimum clear ceiling height of 8 feet;
						1230.1.13.2.	Be limited to one youth;
						1230.1.13.3.	Be padded as specified in Section 1230.2.7;
						1230.1.13.4.	Provide one or more vertical view panels constructed of security glazing. These view panels shall be no more than 4 inches wide nor less than 24 inches long which shall provide a view of the entire room;
						1230.1.13.5.	Provide an audio monitoring system as specified in Section 1230.1.22;
						1230.1.13.6.	Contain a flushing ring toilet, capable of accepting solid waste, mounted flush with the floor, the controls for which must be located outside of the room;
						1230.1.13.7.	Be equipped with a variable intensity, security-type lighting fixture with controls located outside the room;
						1230.1.13.8.	Any wall or ceiling mounted devices must be designed to prohibit access to the youth occupant; and,
						1230.1.13.9	Provide a food pass with lockable shutter, no more than 4 inches high, and located between 26 inches and 32 inches as measured from the bottom of the food pass to the floor.
						1230.1.14	<b>Medical Examination Room.</b> There must be a minimum of one suitably equipped medical examination room in every juvenile facility. Medical examination rooms shall provide the following:
						1230.1.14.1.	Space for carrying out routine medical examinations and emergency care and used for no other purpose;
						1230.1.14.2.	Privacy for youth;
						1230.1.14.3.	Lockable storage space for medical supplies;
						1230.1.14.4.	Not less than 144 square feet of floor space with no single dimension less than 7 feet;
						1230.1.14.5.	Hot and cold running water;

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						1230.1.14.6.	Smooth, non-porous, washable surfaces;
						1230.1.14.7	A medical exam table; and,
						1230.1.14.8	Adequate lighting.
						1230.1.15	<b>Pharmaceutical Storage.</b> Provide lockable storage space for medical supplies and pharmaceutical preparations as specified by Title 15, Section 1438.
						1230.1.16	<b>Dining Areas.</b> Dining areas in juvenile facilities shall contain a minimum of 15 square feet of floor space and sufficient tables and seating for each person being fed. Persons being fed include youth, staff and visitors. Dining areas shall not contain toilets or showers in the same room without appropriate visual barrier.
						1230.1.17	<b>Visiting Space.</b> Space shall be provided in all juvenile facilities for in-person visiting which shall be unobstructed by barriers such as, but not limited to, security glazing or mesh.
						1230.1.18	<b>Institutional Storage.</b> One or more storage rooms shall be provided to accommodate a minimum of 80 cubic feet of storage space per minor. Items to be stored shall be institutional clothing, bedding, supplies and activity equipment.
						1230.1.19	<b>Personal Storage.</b> Each youth in a juvenile facility shall be provided with a minimum of 9 cubic feet of secure storage space for personal clothing and belongings.
						1230.1.20	<b>Safety Equipment Storage.</b> In all juvenile facilities, a secure area shall be provided for the storage of safety equipment, such as fire extinguishers, self-contained breathing apparatus, wire and bar cutters, emergency lights, etc.
						1230.1.21	<b>Janitorial Closet.</b> In all juvenile facilities, at least one securely lockable janitorial closet, containing a mop sink and sufficient area for the storage of cleaning implements, must be provided within the security area of the facility.
						1230.1.22	<b>Audio Monitoring System.</b> In safety rooms, locked holding rooms, locked sleeping rooms, single and double occupancy rooms and dormitories there must be an audio monitoring system capable of actuation by the minor that alerts

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						1230.1.23	<b>Emergency Power.</b> There shall be a source of emergency power in all juvenile facilities capable of providing minimal lighting in all living units, activities areas, corridors, stairs, and central control points, and to maintain fire and life safety, security, communications and alarm systems. Such an emergency power source shall conform to the requirements specified in Title 24, Part 3, Article 700, California Electrical Code, California Code of Regulations.
						1230.1.24	<b>Confidential Interview Room.</b> Confidential interview rooms shall contain a minimum of 60 square feet of floor area. In juvenile halls there shall be a minimum of one suitably furnished interview room for each 30 youth. In camps, there shall be a minimum of one suitably furnished interview room for each facility. This interview room shall provide for confidential consultation with youth.
						1230.1.25	<b>Special Purpose Juvenile Halls.</b> Special purpose juvenile halls shall conform to all minimum standards for juvenile facilities contained in this section with the following exceptions:
						1230.1.25.1.	Physical activity and recreation areas as specified in Section 1230.1.11;
						1230.1.25.2.	Academic classrooms as specified in Section 1230.1.12;
						1230.1.25.3.	Medical examination room as specified in Section 1230.1.14; and,
						1230.1.25.4.	Dining areas as specified in Section 1230.1.16.
						1230.1.26	<b>Court Holding Room for Youth.</b> A court holding room shall:
						1230.1.26.1.	Contain a minimum of 10 square feet of floor area per youth;
						1230.1.26.2.	Be limited to no more than 16 youth;
						1230.1.26.3.	Provide no less than 40 square feet of floor area and have clear ceiling height of 8 or more feet;
						1230.1.26.4.	Contain seating to accommodate all youth as specified in Section 1230.2.8;
						1230.1.26.5.	Contain a toilet, wash basin and drinking fountain as specified in Section 1230.2;

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						1230.1.26.6.	Maximize visual supervision of youth by staff; and,
						1230.1.26.7	A mirror of a material appropriate to the level of security shall be provided as specified in Section 1230.2.11.
						1230.1.27	<b><u>Program and activity Areas.</u></b> All juvenile facilities shall include adequate space for specific programs in addition to recreation and exercise areas.
						1230.2	<b><u>DESIGN CRITERIA FOR FURNISHINGS AND EQUIPMENT.</u></b>
						1230.2.1.	<b><u>Toilets/Urinals.</u></b> All toilet areas shall provide privacy for the youth and help reduce the risk of voyeurism without mitigating staff's ability to supervise. Toilets must be available in a ratio to youth as follows:
						1230.2.1.1.	Juvenile halls 1:6;
						1230.2.1.2.	Camps 1:10; and
						1230.2.1.3.	Locked holding rooms 1:8:
							One toilet and one urinal may be substituted for every fifteen males.
						1230.2.2	<b><u>Wash Basins.</u></b> In living units, wash basins must be available in a ratio to youth as follows:
						1230.2.2.1.	Juvenile halls 1:6;
						1230.2.2.2.	Camps 1:10; and,
						1230.2.2.3.	Locked holding rooms 1:8:
							Wash basins must be provided with hot and cold or tempered water.
						1230.2.3	<b><u>Drinking Fountains.</u></b> In living areas and indoor and outdoor recreation areas, drinking fountains must be accessible to youth and to staff.

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						1230.2.3.1.	The drinking fountain bubbler shall be on an angle which prevents waste water from flowing over the drinking bubbler; and,
						1230.2.3.2.	The water flow shall be actuated by a mechanical means.
						1230.2.4	<b>Showers.</b> Shower areas shall provide privacy for the youth and help reduce the risk of voyeurism without mitigating staff's ability to supervise. Showers shall be available to all youth on a ratio of at least one shower or bathtub to every six youth. Showers shall be provided with tempered water.
						1230.2.5	<b>Beds.</b> Beds shall be at least 30 inches wide and 76 inches long and be of the pan bottom type. Beds shall be at least 12 inches off the floor and spaced no less than 36 inches apart. Bunk beds must have no less than 33 inches vertically between the solid bottoms. In secure facilities, the bunks shall be securely anchored against the floor and/or wall.
						1230.2.6	<b>Lighting.</b> Lighting in locked sleeping rooms, single occupancy rooms, double occupancy rooms, dormitories, dayrooms and activity areas shall provide not less than 20 foot candles (538 lx) of illumination at desk level. Night lighting is required in these areas to provide good visibility for supervision and be conducive to sleep.

Not applicable to this project	Does not comply with regulations	Unable to verify at this submittal	Information/clarification requested	Please note & respond to comment	Complies with Title 24 regulations	<b>REFERENCE</b>	<b>REGULATION NARRATIVE</b>
						1230.2.7	<p><b>Padding.</b> In safety rooms, padding shall cover the entire floor, door, walls and everything on the walls, to a clear height of 8 feet. Benches or platforms are not to be placed on the floor of this room.</p> <p>All padded rooms must be equipped with a tamper-resistant fire sprinkler as approved by the State Fire Marshal. All padding must be:</p> <ul style="list-style-type: none"> <li>.1 Approved for use by the State Fire Marshal;</li> <li>.2 Nonporous to facilitate cleaning;</li> <li>.3 At least ½ inch thick;</li> <li>.4 Of a unitary or laminated construction to prevent its destruction by teeth, hand tearing or small metal objects;</li> <li>.5 Firmly bonded to all padded surfaces to prevent tearing or ripping; and,</li> <li>.6 Without any exposed seams susceptible to tearing or ripping</li> </ul>
						1230.2.8	<p><b>Seating.</b> Seating shall be designed to the level of security. When bench seating is used, 18 inches of bench is seating for one person.</p>
						1230.2.9	<p><b>Weapons Lockers.</b> Weapons lockers are required in all secure juvenile facilities and shall be located outside the secure area of the facility. Weapons lockers shall be equipped with individual compartments, each with an individual locking device.</p>
						1230.2.10	<p><b>Security Glazing.</b> Security glazing shall comply with the minimum requirements of one of the following test standards: American Society for Testing and Materials, ASTM F 1233-98, Class III glass, or; California Department of Corrections, CDC 860-94d, Class C glass, or H. P. White Laboratory, Inc., HPW-TP-0500.02, Forced Entry Level III.</p>
						1230.2.11	<p><b>Mirrors.</b> A mirror of a material appropriate to the level of security must be provided near each wash basin specified in these regulations.</p>

	<b>TENTATIVE BOARD RATED CAPACITY</b>
--	---------------------------------------

**THESE ITEMS ARE NOT COVERED BY REGULATIONS, BUT THEY ARE AREAS OF SPECIAL CONCERN:**

- Security doors and locks
- Door swing
- Corridor widths (Defined in 1230.1.4 as 8 ft wide in living units)
- Wall finishes
  - ◆ Smooth and scuff proof
  - ◆ Impervious at toilet
- (Required in 13-201(c)6 B(12) where operationally and mechanically appropriate) Ventilation
- Security fasteners in inmate areas
- Hose bibs in pertinent areas
- Detention registers

## TITLE 24 COMPLIANCE REVIEW

### 2019 JUVENILE REGULATIONS

#### COMMENTS:

NO.	TITLE 24 REFERENCE	STANDARD	COMMENT
1.	13-201(c)3	Program Statement	
2.	13-201(c)6.B(1)	Fire safety	
3.	13-201(c)6.B(2)	Suicide hazards	
4.	13-201(c)6.B(3)	Health and sanitation	
5.	13-201(c)6.B(4)	When adding new sleeping rooms	
6.	13-201(c)6.B(5)	Staff and safety	
7.	13-201(c)6.B(6)	Heating and cooling	
8.	13-201(c)6.B(7)	Acoustics	
9.	13-201(c)6.B(8)	Spaces for the disabled	
10.	13-201(c)6.B(9)	Security	
11.	13-201(c)6.B(10)	Medical/mental health care housing and treatment space	
12.	1230.1.1	Reception/Intake admission	
13.	1230.1.2	Locked holding room	
14.	1230.1.3	Natural light	
15.	1230.1.4	Corridors	
16.	1230.1.5	Living unit	
17.	1230.1.6	Locked sleeping rooms	
18.	1230.1.7	Single-occupancy sleeping rooms	
19.	1230.1.8	Double-occupancy sleeping rooms	
20.	1230.1.9	Dormitories	
21.	1230.1.10	Dayrooms	
22.	1230.1.11	Physical activity and recreation areas	
23.	1230.1.12	Academic classrooms	
24.	1230.1.13	Safety room	
25.	1230.1.14	Medical examination room	

26.	1230.1.15	Pharmaceutical storage	
27.	1230.1.16	Dining areas	
28.	1230.1.17	Visiting space	
29.	1230.1.18	Institutional storage	
30.	1230.1.19	Personal storage	
31.	1230.1.20	Safety equipment storage	
32.	1230.1.21	Janitorial closet	
33.	1230.1.22	Audio monitoring system	
34.	1230.1.23	Emergency power	
35.	1230.1.24	Confidential interview room	
36.	1230.1.25	Special Purpose juvenile halls	
37.	1230.1.26	Court holding room for minors	
38.	1230.1.27	Program and Activity Areas	
39.	1230.2.1	Toilets/urinals	
40.	1230.2.2	Wash Basins	
41.	1230.2.3	Drinking fountains	
42.	1230.2.4	Showers	
43.	1230.2.5	Beds	
44.	1230.2.6	Lighting	
45.	1230.2.7	Padding	
46.	1230.2.8	Seating	
47.	1230.2.9	Weapons lockers	
48.	1230.2.10	Security Glazing	
49.	1230.2.11	Mirrors	
50.	-----	Tentative Board Rated Capacity	
51.	-----	General Comments	